

customer

# A pathway to DER ubiquity: Distribution voltage management, smart inverters and dynamic operating envelopes

QUT, November 2023




Part of Energy Queensland



# Acknowledgement of Country





# Ergon Energy Network & Energex




- Ergon Energy Distribution Network
- Administration Centre
- Ergon Energy Isolated Supply
- Depots
- Energex Distribution Network
- ◆ Isolated Supply

## Our 17 service areas

- |                  |                     |                     |
|------------------|---------------------|---------------------|
| 1 Far North      | 7 Capricornia       | 13 Brisbane North   |
| 2 Tropical Coast | 8 Bundaberg Burnett | 14 Brisbane Central |
| 3 Herbert        | 9 Fraser Burnett    | 15 Brisbane South   |
| 4 Flinders       | 10 Darling Downs    | 16 Ipswich Lockyer  |
| 5 Pioneer        | 11 South West       | 17 Gold Coast       |
| 6 Central West   | 12 Sunshine Coast   |                     |




**210,000km**  
POWERLINES  
(overhead and underground)



**34** POWER STATIONS  
(including network-connected Barcaldine)



**800,000**  
SOLAR ENERGY SYSTEMS  
CONNECTED



**43**  
LARGE-SCALE SOLAR  
ENERGY CONNECTIONS




**1.7million**  
km<sup>2</sup>  
SERVICE AREA




**1.7 million**  
POWER POLES




**ENERGEX**  
**5,221 MW** network-wide peak/  
maximum demand  
**237 MW** network-wide  
minimum demand



**ERGON NETWORK**  
**2,637 MW** network-wide peak/  
maximum demand  
**799 MW** network-wide  
minimum demand




**UNPLANNED OUTAGES**  
Energex Ergon Network  
**0.66** **2.15**  
(average per customer a year)



# Ongoing uptake of solar PV


## SOLAR PV AC CAPACITY ENERGEX AND ERGON ENERGY COMBINED




NB. Solar farms connected to Powerlink's transmission network are not included




# Regional Queensland




% refers to percentage of total customers which have rooftop solar Grouped by the Zone Substation



# South East Queensland




% refers to percentage of total customers which have rooftop solar Grouped by the Zone Substation




Sources: Esri, HERE, Garmin, Intermap, increment P Corp., GEBCO, USGS, FAO, NPS, NRCAN, GeoBase, IGN, Kadaster NL, Ordnance

# Distributed Solar PV (DPV) continues to increase reverse flows




# Queensland price setter by time of day, Q3 2023 vs Q3 2022

## Q3 2023




Queensland price setter by time of day, Q3 2023 vs Q3 2022

Q3 2023



Occurrence of negative price by time of day – Q3s 2021-2023



[Q3 2023 Wholesale markets quarterly report.pdf \(aer.gov.au\)](https://www.aer.gov.au/publications-reports/quarterly-reports/q3-2023-wholesale-markets-quarterly-report.pdf)

[Quarterly Energy Dynamics Q3 2023 Report.pdf \(aemo.com.au\)](https://www.aemo.com.au/energy-reports/quarterly-energy-dynamics/q3-2023-quarterly-energy-dynamics-report.pdf)




# CIGRE AU C6 Survey on Distribution Voltage Management





# Global survey on distribution voltage management

- Focused specifically on voltage management practices associated with the medium and low voltage electricity networks
- This is an area that has received increased attention and innovation, with the rise of DER, reverse flows and increasing customer awareness
- Voltage constraints have emerged first on distribution networks with growing distributed PV, spurring innovations in standards, voltage remediation, LV technologies, smart inverters and MV regulation
- This initially began as a survey of Australian DNSPs but with the support of CIGRE Australia extended to a global sample

# Global distribution of respondents




# Respondents' low voltage ranges






What is the current LV supply range in your jurisdiction?  
Are there any plans to change the LV supply range?

# 4-wire low voltage standards




# Reactive work mostly for overvoltage or undervoltage?




Does your organisation undertake reactive work more commonly to address undervoltage or overvoltage on LV networks?  
 Does your organisation undertake reactive manual tap changes of distribution transformers supplying LV networks where voltage constraints are identified?  
 Does your organisation undertake proactive manual tap changers of distribution transformers supplying LV networks where voltage constraints are expected/forecast ?

# New LV distribution technologies


### Voltage Regulating Distribution Transformers



### LV Statcoms




### LV Regulators



# Smart inverter functions\*

## Inverter Grid Support Functions




\*heavily biased sample as a result of Australian regulations mandating AS/NZS 4777.2 with Q(V) and P(V)



# MV regulation

## MV Regulation Techniques



# Noteworthy takeaways from the survey

- Transitions to the 230V standard are progressing slowly but surely
- Overvoltage associated with PV has become the primary distribution voltage management constraint globally
- Undervoltage constraints associated with EV and heat pumps emerging
- VRDTs are leading LV regulators and LV statcom deployments, especially in Europe
- Australia [Q(V) & P(V)] and Germany [ $\cos \phi(P)$ ] have the most consistent although distinct approaches to LV inverter grid support functions
- Both fixed MV regulation and line drop compensation are still widely used, with many reports of reducing set points/float levels, closed loop regulation is under development in a small but growing number of distribution utilities

# Distribution voltage management




# Improved distribution voltage management


- Targeted distribution transformer tap reductions
  - Targeted at sites with high PV penetrations and modest peak demand voltage drop
- Widespread MV reductions to transition from the 240V standard to 230V
  - From 225.6-254.4V to 216-253V LV range
  - Increased voltage headroom for reverse flows
  - Median supply voltage compliance with Preferred range 225-244V (AS 61000.3.100)
- Application of line drop compensation to buck MV during reverse flow & minimum demand
  - Applied at zone substations and on MV feeder regulators
  - Reduces voltage spread at end of distribution feeders and accommodates additional feeder voltage rise
  - Constrained by buck tap range on some On Load Tap Changers (OLTCs)



## Ergon Energy




## Energex




**Overvoltage at the Transformer ( $V99\% > 253V$ )**



## Ergon Energy Network



## Energex





**Quality of Supply Enquiries per 10,000 customers**



## Ergon Energy

## Energex



- Computer screen movement
- Flickering lights
- Interference (TV, VDU, Radio)
- Motor start problem
- Other - QoS
- Voltage dip - severe
- Voltage swell

- Equipment mal-operation
- High voltage (bulbs blowing)
- Low voltage (dim lights)
- Noise from appliances or equipment
- Solar PV Issues
- Voltage spike

- Low supply voltage
- TV or radio interference
- Voltage dip - severe
- Waveform distort or unbal


- Noise from appl or lights
- Unknown
- Voltage spike

- Solar PV related
- Volt dip - minor or nuisance
- Voltage swell


# Quality of Supply Enquiry Categories

# Voltage constrained VS Capacity constrained Distribution transformers


SC2160780 Load profile - Voltage constrained




SC2196527 Load profile - Capacity constrained



SC2160780 Voltage profile - Voltage constrained



SC2196527 Voltage profile - Capacity constrained






# Steady-state voltage distribution



# Transformer Monitoring – Jan 2021


Voltage Measurements for Transformer Monitoring on Ergon Energy and Energex Networks in January 2021



NB. This sample is dominated by 21009 Energex monitors

# Low Voltage Monitoring – Jan 2021


Voltage Measurements for LV Monitoring  
on Ergon Energy and Energex Networks in January 2021



NB. These monitors are often at the end of the LV network

# Low Voltage Monitoring – Peak week Feb 2021

Voltage Measurements for LV Monitoring  
on Energen Network in Peak Week February 2021



NB. These monitors are often at the end of the LV network

# Smart Inverters and Grid Support Functions (GSF)

AS/NZS 4777.2:2020 Grid connection of energy systems via inverters, Part 2: Inverter requirements





# Large Reactive Power Capability




Figure 2.1 — Minimum reactive power capability

# Volt-var response, mitigating voltage rise from reverse flow




Figure 3.2 — Example curve for the volt-var control mode AS/NZS 4777.2:2020

# Volt-watt response, limiting active power above 253V





Figure 3.1 — Example curve for the volt-watt response mode



# Inverter Voltage Response – AS/NZS 4777.2 Australia A Region



— P (watts) — S (voltamperes) — cosφ — Q (vars) ..... Q (min capability) ..... Vnom-max

# For power system security, active power response to under and over frequency $P(f)$




Figure 4.1 — Example frequency response for a decrease in frequency for an inverter that has a reduced output

# + Extensive voltage disturbance ride-through requirements




Figure 4.5 — Example of two multiple voltage disturbance events where the inverter is required to remain in continuous operation




# Curtailment associated with volt-var and volt-watt

[Impacts of Voltage-Based Grid-Support Functions on Energy Production of PV Customers: Preprint \(nrel.gov\)](#)

[Real-world data analysis of distributed PV and battery energy storage system curtailment in low voltage networks - ScienceDirect](#)


TABLE II. IMPACT OF ACTIVATING GSF CONTROL ON PV SYSTEMS AND ENERGY CURTAILMENT AT DIFFERENT PENETRATION LEVELS

Metrics	GDML penetration levels					
	175%		370%		600%	
	VV	VV-VW	VV	VV-VW	VV	VV-VW
Max GSF Curt.	1.8%	2.3%	1.8%	3.7%	1.8%	5.7%
Ave. GSF Curt.	0.10%	0.07%	0.15%	0.13%	0.24%	0.23%
Ave. Incr. Gen.	2.1%	2%	2.7%	2.6%	2.7%	3%
Ave. Net Gen.	2%	1.9%	2.5%	2.4%	2.4%	2.8%



[Download : Download high-res image \(387KB\)](#)  
[Download : Download full-size image](#)

Fig. 10. Measured and modelled V-Var curtailment scenarios: a) D-PV only sites, b) D-PV coupled with BESS sites.



[Download : Download high-res image \(701KB\)](#)  
[Download : Download full-size image](#)

Fig. 11. a) V-Watt power reduction line and voltage threshold identification for a sample D-PV inverter, b) example daily operation with V-Watt curtailment.

Fig. 1. The two voltage grid support functions and the settings used in this study


Fig. 6. Weekly customer energy curtailment versus maximum voltage for the high PV penetration case

# Changing reactive power demand



# PV inverters with GSF are absorbing reactive power at minimum demand

## 110kV Bulk Supply Minimum Demand




— Active Power (MW)    — Reactive Power (Mvar)




# High Demand

110kV Bulk Supply High Demand



# Active Power Vs Reactive Power

110kV Bulk Supply Active Power Vs Reactive Power



PV Reactive Compensation


Significant var injection now occurs at light load  
-exacerbating OLTC buck tap limitations




# Dynamic Operating Envelopes (DOE)




# Dynamic Operating Envelopes

- A DOE specifies a varying operating range, typically at the connection point, for exports and/or imports.
  - This can apply to a range of DER including PV, BESS and EV.
  - It can be used in conjunction with autonomous DER responses to ensure network/system constraints are not breached by DER operation.
  - DOE differ from demand response in that they do not dispatch or target a response; but specify the limits of active power import or export. Within the limits DER behaviour is unaffected.
  - DOE also permit a range of behind-the-meter responses to achieve the specified limit – curtailment isn't necessarily required.
  - While DOE are initially limited by existing visibility and systems, as capabilities scale and grid visibility increases, the DOE we send to active DER can be optimised
  - Now supported by two protocols IEEE2030.5 CSIP-AUS and OpenADR 3.0
- 


# Native/underlying Load (before DER operation)



# Net Load with significant PV generation




# Net Load with additional PV generation can breach capacity constraints





# Net Load with significant PV generation

## Newer PV managed with DOE



# DOE can manage constraints associated with load also





**Figure 5: Model developed in PowerFactory of study case on a section of the GLY15A**



# Existing 50% penetration




Figure 14: Transformer loading in existing solar PV scenario. Transformer loading threshold (black dotted line).

# Simulating 100% PV penetration




Figure 25: Transformer loading in 100% solar PV scenario. Transformer loading threshold (black dotted line).





Figure 24: Network voltages (phase A) for all cases in 100% solar PV scenario. Overvoltage tripping limit 257 V (red dotted line), upper voltage threshold 253 V (black dotted line), lower voltage threshold 216 V (blue dotted line).


# Example of a Dynamic Connection




# Example Unmanaged Household Load



# Adding Solar PV with a static export limit



# Solar PV with a Dynamic Connection



Note increased generation when self consumption increases

Export may be limited through middle of day due to excessive reverse flows


Extra Solar PV-Dynamic

Unmanaged load

Net Demand

Dynamic Export limit

# Adding an EV Charging Station to the Dynamic Connection



# Electrification – surfing CER wave





# Electrification of residential & commercial loads also present opportunities for customer DER flexibility to reduce energy costs and curtailment

Figure 63 Components of Queensland residential electricity consumption forecast, ESOO Central scenario, 2023-24 to 2052-53 (TWh)







Figure 64 Components of Queensland business electricity consumption forecast, ESOO Central scenario, 2023-24 to 2052-53 (TWh)



Note: Small non-scheduled combines PVNSG and ONSG.



Most new electrified demand is flexible (suitable for demand management/smart charging via DERMS) limiting contribution to peak demand, and reducing curtailment, whilst increasing distribution network utilisation



# Increasing DER integration supported by emerging DSO capabilities

- In a bit over a decade solar PV capacity in Qld has increased 1000 fold, primarily on the distribution network
- The 230V standard & improved distribution voltage regulation accommodates more voltage rise/PV
- Advanced autonomous inverter GSF mitigate impacts and maximise PV penetration
- DOE enables active DER management & DER service participation to maximise hosting capacity
- This and other DSO capabilities enable customers to surf the DER wave

## References

- 1) Ergon Energy Network, Distribution Annual Planning Report, <https://www.ergon.com.au/network/network-management/future-investment/distribution-annual-planning-report>
- 2) Energex , Distribution Annual Planning Report, <https://www.energex.com.au/about-us/company-information/company-policies-And-reports/distribution-annual-planning-report>
- 3) Zone substation load data, <https://www.energex.com.au/our-network/network-data/zone-substation-load-data>
- 4) AER, Q3 2023 Wholesale markets quarterly report, [https://www.aer.gov.au/system/files/Q3\\_2023\\_Wholesale\\_markets\\_quarterly\\_report.pdf](https://www.aer.gov.au/system/files/Q3_2023_Wholesale_markets_quarterly_report.pdf)
- 5) AEMO, Quarterly Energy Dynamics Q3 2023 Report, <https://aemo.com.au/-/media/files/major-publications/qed/2023/qed-q3-2023-report.pdf>
- 6) Peter Kilby, 2019, "Voltage Management on Distribution Networks with High PV Penetrations", QUT PECT, <https://cloudstor.aarnet.edu.au/plus/s/sAwMa8JhIPoPw0d>
- 7) Energex, Transformer monitoring data, <https://www.energex.com.au/our-network/network-data/transformer-monitoring-data>
- 8) Grid connection of energy systems via inverters, Part 2: Inverter requirements, [AS/NZS 4777.2: 2020](#)
- 9) J. Giraldez, M. Emmanuel, A. Hoke, S. Suryanarayana, Impacts of Voltage-Based Grid-Support Functions on Energy Production of PV Customers: Preprint, NREL, <https://www.nrel.gov/docs/fy20osti/72701.pdf>
- 10) B. Yildiz, N. Stringer, T. Klymenko, M. Samhan, G. Abramowitz, A. Bruce, I. MacGill, R. Egan, A. Sproul, Real-world data analysis of distributed PV and battery energy storage system curtailment in low voltage networks, <https://www.sciencedirect.com/science/article/pii/S1364032123005531#sec6>
- 11) C.G. Kaloudas, L.F. Ochoa, B. Marshall, S. Majithia and I. Fletcher, "Assessing the Future Trends of Reactive Power Demand of Distribution Networks", IEEE Trans. on Power Syst., vol. 32, no. 6, 2017
- 12) Standards Australia, Smart Energy Profile Application Protocol, AS 5385:2023
- 13) Standards Australia, Common Smart Inverter Profile — Australia with Test Procedures, SA HB 218:2023
- 14) OpenADR Alliance, [OpenADR 3.0](#)
- 15) Energex and Ergon Energy Network, [Dynamic Connections for energy exports](#)
- 16) AEMO, 2023 Electricity Statement of Opportunities, [https://aemo.com.au/-/media/files/electricity/nem/planning\\_and\\_forecasting/nem\\_esoo/2023/2023-electricity-statement-of-opportunities.pdf](https://aemo.com.au/-/media/files/electricity/nem/planning_and_forecasting/nem_esoo/2023/2023-electricity-statement-of-opportunities.pdf)